

Optimizing Cooling Tower to Reduce Water and Costs


TEMA – San Antonio Chapter


March 17, 2026

Presented by Annikki Chamberlain, Mimir Water


The Mimir Water Efficiency Hierarchy

Strategy for Longterm Water Management





Optimal Cycles



Waste vs Scale



Waste



Scale


Common Problems

Mechanical Problems:


- Faulty Valves
- High Water Level
- Controller Power
- Sensor Issues
- Empty Chemical

Operational Problems:

- Miscalibrated Sensors
- Low/High Set Point



Operational Control = Water Efficiency







No control = water waste

Good control = water efficiency

Service Reports

Regular Service Reports provide crucial information on tower performance and issues.

Integrate cooling tower service reports into you normal routines.

Main Building - Main System				
Test	City Water	Cooling Tower		
Conductivity (as mmhos)	1170 0 min	2380 0 min		
pH		8.50 8.5 - 9.5		
Hardness, calcium (ppm as CaCO ₃)	140 0 min	280 200 - 700		
Alkalinity, P (ppm as CaCO ₃)	0 0 min	50 0 min		
Alkalinity, M (ppm as CaCO ₃)	140 0 min	250 300 - 700		
Sodium Chloride (NaCl)	200 0 min	320 0 min		
Phosphonate (ppm as PO ₄ /OTT)	2.1 0 min			
PTSA Handheld		28 60 - 100		
Temperature °F		115 0 min		
 Conductivity (UM) Cycles (Calculated)		2.0 2.5 - 4.5		
 Calcium (CA) Cycles (Calculated)		2.0 2.5 - 4.5		
 Alkalinity Cycles (Calculated)		1.8 2.5 - 4.5		
 Chloride (NaCl) Cycles (Calculated)		1.6 2.5 - 4.5		
 LSI (temp in F) (Calculated)		1.7 2 - 2.7		

Opening Comment

The purpose of today's visit was to perform bi-monthly service and testing please see the details below.

City Water Online

I ran a full water analysis on the city water.

Cooling Tower Online

- Tower was running during visit.
- Checked chem drum level.
 - Cleaned conductivity probe.
 - Flushed sensor line.
 - Tower is constantly overflowing.
 - Slug fed inhibitor for 5 minutes.

Waste: Expensive




Cooling Tower


Online

Tower was running during visit.

- Checked chem drum level.
- Cleaned conductivity probe.
- Flushed sensor line.
- Tower is constantly overflowing.
- Slug fed inhibitor for 5 minutes.



Scale: Very, Very Expensive



New Tower

Online

Big problems with the new tower this visit. Upon arrival the first thing I noticed was that the controller was turned off. We have had this issue in the past and it's going to cause major issues. The power out here is on a GFI and it trips sometimes. So this tower has been cycling up since the 4th. This tower was 4-5 times cycled up higher than it should be and that's a sure fire way to get scale in the tower. I have it up and going again and is in the process of blowing down to get us back in range.

SOPs

Regular but simple tower checks will avoid 90% of the waste/scale problems quickly.

Integrate a simple SOP into cooling tower management program.

MIMIR WATER'S 5 RULES FOR COOLING TOWER WATER CONTROL

RULE 1 – NO OVERFLOW

If water is overflowing:

- Lower water level with float valve or level sensor
- Check that float or solenoid closes fully

No overflow → OK

RULE 2 – NO UNRESOLVED ALARMS

If controller has an alarm:

- Identify it
- Correct it
- Do not ignore it

No alarm → OK

*If **NO FLOW** alarm appears:

- Tower OFF → OK
- Tower RUNNING → Check recirculation line or contact service provider

RULE 3 – HIGH CONDUCTIVITY¹ → BLOWDOWN MUST OPEN

If High Conductivity alarm:

- Run manual blowdown
- Confirm valve opens
- Confirm water discharges to drain

RULE 4 – LOW CONDUCTIVITY² → BLOWDOWN MUST CLOSE

If Low Conductivity alarm:

- Confirm blowdown valve is fully closed
- If reading is >150 $\mu\text{S}/\text{cm}$ below setpoint → valve likely stuck open
- Doublecheck for overflow


RULE 5 – CONDUCTIVITY STAYS NEAR SETPOINT

Conductivity should remain within $\pm 200 \mu\text{S}/\text{cm}$ of setpoint.

If outside this range (even without alarm):

- Verify controller reading
- Clean probe if needed
- Check blowdown valve operation
- Contact service provider

Within Range → OK



NEVER TRUST A VALVE!

¹ Require Water Treatment Provider to set high and low conductivity alarms +/- 500 from setpoint
Questions: support@mimirwater.com

Monitor Performance, Not Water

Cycles of Concentration (COC) is the standard performance metric.

Low COC

Too Much Blowdown
Stuck Valve
Sensor Issue
Low SetPoint
Water Waste

Target COC


Water Quality
Water Treatment
Operating Conditions

High COC

Not Enough Blowdown
Stuck Valve
Sensor Issue
High Set Point
Scale

Water Use vs Efficiency

Makeup & Blowdown Water




Makeup Water :	330,010.00 G	BlowDown Water :	119,409.00 G	COC (Simplified) :	2.764
----------------	--------------	------------------	--------------	--------------------	-------

Departure from Optimal

[PDF](#)

Makeup & Blowdown Water



Makeup Water : 88,332.00 G

BlowDown Water : 21,512.00 G

COC (Simplified) : 4.106

School District Cooling Tower

Domestic Winter Use:
50k gallon per month

Domestic Summer Use:
400k gallon per month



Case Study: Prevent Waste


Alert: Low Efficiency

Low Efficiency






Too Much Blowdown
Stuck Valve
Sensor Issue
Low Set Point
Water Waste



Makeup & Blowdown Water



Makeup Water :	203,383.00 G	BlowDown Water :	147,997.00 G	COC (Simplified) :	1.374
----------------	--------------	------------------	--------------	--------------------	-------

Sodium Nitrite (ppm as NaNO ₂)			650 800 min	
Phosphonate (ppm as PO ₄ /OTT)	2.1 0 min	3.5 4 - 8		
 Calcium (CA) Cycles (Calculated)		1.1 1.7 - 2.5		
 Conductivity (UM) Cycles (Calculated)		1.1 1.7 - 2.5		
 Chloride (NaCl) Cycles (Calculated)		1.2 1.7 - 2.5		
 Alkalinity Cycles (Calculated)		1.3 1.7 - 2.5		
Temperature ^F		110 0 min		
 LSI (temp in F) (Calculated)		1.3 1.7 - 2.5		

Opening Comment

- The purpose of today's visit is for the biweekly testing and service of the tower and chemical equipment.

City Water Online

- Ran full water analysis on incoming city water.
- Setpoint to 4300 to maintain LSI.


Cooling Tower Online

- Tower online at this time.
- Conductivity is below setpoint.
- Tower is running lower cycles due to change in city water quality also due to the conductivity probe being out of calibration.
I have calibrated the probe to current system conductivity and tower is blowing down to meet set point.
- Inhibitor is within range.



[PDF](#)

Makeup & Blowdown Water



Makeup Water : 240,303.00 G

BlowDown Water : 160,331.00 G


COC (Simplified) : 1.499

School District Cooling Tower



Gallons Saved: 540,000



Dollars Saved: \$10,000/month

Cost: \$0



Advanced Diagnostics





Start Date:


01/28/2026 09:29 PM


End Date:


03/16/2026 09:29 PM


Submit

Total Make-Up (Input) Total Blow Down (Output) CoG-Average Upper-CoG-Threshold Lower-CoG-Threshold Target-CoG



 **434,572.00**
MAKEUP WATER (GALLONS)


 **7,874.00**
BLOWDOWN WATER (GALLONS)


 **55.19 COC**
TARGET 3.00 COC





Start Date: 03/12/2026 09:29 PM End Date: 03/16/2026 09:29 PM

Total Make-Up (Input) Total Blow Down (Output)




 **40,857.47**
MAKEUP WATER (GALLONS)

 **5.50**
BLOWDOWN WATER (GALLONS)


 **7,428.63 COC**
TARGET 3.00 COC


Start Date: 02/01/2026 09:29 PM End Date: 02/07/2026 09:29 PM [Submit](#)

Total Make-Up (Input) Total Blow-Down (Output)



 **18,951.00**
MAKEUP WATER (GALLONS)


 **898.00**
BLOWDOWN WATER (GALLONS)

 **21.10 COC**
TARGET 3.00 COC

Case Study: "it's on our daily checks"

PDF

Makeup & Blowdown Water



Makeup Water :	109,851.00 G	BlowDown Water :	67,725.00 G	COC (Simplified) :	1.622
----------------	--------------	------------------	-------------	--------------------	-------

Case Study: “it’s on our daily checks”



Conductivity
: 10900!

Questions?

- Annikki Chamberlain, Mimir Water
 - annikki@mimirwater.com
- Patrick Middleton, SAWS
 - Patrick.Middleton@saws.org

March 17, 2026

Commercial Conservation Programs

Patrick Middleton

Project Coordinator, Conservation


Texas Energy Managers Association



Conservation Investment

Commercial Conservation Fund

- Commercial conservation fee recommended by the Community Conservation Committee to fund commercial conservation programs. Dedicated commercial conservation meter fee approved by City Council in 1997.



Landscape Irrigation

Annual Irrigation Checkup

- **Reasonable Regulation**
 - Prevent water waste
 - Improve landscape irrigation efficiency
 - Establish effective communication channels




Who's Required?

- **Large Use (over 1M gals)**
- **Large Property (over 5 acres)**


Landscape Irrigation

Irrigation Rebates




Irrigation Design Rebate

Efficiency targeted changes to irrigation systems.



Smart Irrigation Controller Rebate

Upgrade single-controller systems to approved smart model.




Smart Irrigation System Rebate

Upgrade existing systems to central control smart network.

Electronic Water Meters

Leak Alerts


- Alert Sent if >5 gph ($.08$ gpm) of continuous use for >48 hrs
- Onsite leak detection: GPM and Total Gallons digital screen



Understanding Data

WaterSmart Customer Portal



- Customers have the option to sign up for additional use notifications
 - High Use Notifications
 - Bill Forecast Notifications
 - Unplanned Use Notifications
- Customers have the option to combine accounts and add additional users
- Continuous Use Response



saws.watersmart.com

Custom Rebates


- Designed for flexibility
- Projects reviewed individually
- Rebate amount based on acre-feet of water saved over a specified period
- Rebate paid up front or yearly based on performance
- \$1,255 per acre-foot for peak
 - \$627 per acre-foot year-round
 - Up to 50% of the installation cost



Cooling Tower Regulations

City Code Ch. 34 / SAWS Utility Service Regulations

- All cooling towers, not utilizing recycled water, shall operate a minimum of four (4) cycles of concentration
- All cooling towers shall be operated with conductivity controllers, as well as make-up and blowdown meters.



March 17, 2026

Commercial Conservation Programs

Patrick Middleton

Project Coordinator, Conservation

Texas Energy Managers Association

